



Email from Hereford and Worcester Fire and Rescue Service of 13 January 2026

Hi Matthew,

Apologies I've been on annual leave so have only just seen the review of licence.

I am unable to attend the sub-committee meeting on the 19th but in regards to fire safety, the premises is not compliant.

Mr Hassan is not responding to any emails, phone calls, or in person visits and there is no evidence to suggest any of the works required have been completed.

I have attached a copy of the fire safety matters letter issued to Mr Hassan.

I am still waiting for (which is now overdue):

- A fire risk assessment
- Weekly fire alarm test records
- 6 monthly service certificate of the fire alarm
- Monthly emergency lighting test records
- Annual emergency lighting service certificate
- Mains Electrical Condition Report
- PAT test certificate
- Staff training records
- Fire extinguisher service certificate
- Monthly fire extinguisher check records

Regards

Charly Perkins AIFireE | Fire Safety Inspector | Protection Department
Hereford & Worcester Fire and Rescue Service |



[Click to donate](#)

#ThinkSprinkler

Installing sprinklers protects life and property

Q HWFire Sprinklers

