

**201962 - PROPOSED ERECTION OF THREE SUSTAINABLE HOLIDAY LODGES
AT HOPEFIELD COTTAGE, HAYNALL, LITTLE HEREFORD, LUDLOW, SY8 4BG**

**For: Mrs Fletcher per Mr Jim Hicks, Second Floor Offices, 46 Bridge Street,
Hereford, Herefordshire, HR4 9DG**

ADDITIONAL REPRESENTATIONS

The following email has been submitted by the applicant's agent:

We have noted from your committee report for the above application that there was an outstanding matter pertaining to the emergency storage capacity of the proposed effluent pump chamber as raised by the council's land drainage consultant. Though we note there is no objection from land drainage, subject to condition, we thought it prudent to update the drainage strategy to clarify this point.

Please therefore find enclosed the project drainage engineer's amended drainage strategy which now specifies 24 hours emergency storage capacity in the pump chamber, in line with the BBLP comments.

OFFICER COMMENTS

The revised drainage strategy can be referred to in the list of approved documents covered by condition 2 of the recommendation.

CHANGE TO RECOMMENDATION

No change to the recommendation