



CERTIFICATE OF MAINTENANCE

FIRE FIGHTING EQUIPMENT

THIS CERTIFICATE CONFIRMS THAT CENTRAL FIRE PROTECTION HAVE COMPLETED THE ANNUAL SERVICE OF YOUR FIRE FIGHTING EQUIPMENT AS LISTED BELOW IN ACCORDANCE WITH BRITISH STANDARD 5306 part 3. 2009.

Customer name.
Customer no
Address
Post code.
Telephone no.

Date	engineer
------	----------

type	water	foam	CO2	powder	Wet chemical	blanket
qty						

British Standard 5306:Part 3:2009

Routine inspection by user.

It is recommended that regular inspection of all extinguishers, gas charges and replacement charges should be carried out by the user or by the users representative at intervals, to make sure that the appliances are in their proper position and have not been discharged, or lost pressure (in the case of extinguishers fitted with pressure indicator) or suffered obvious damage. The frequency of inspection should not be less than quarterly and preferably at least monthly. The user should replace the extinguishers not available for service by serviceable extinguishers.